

## Legionella Questions for C3IC, January 2014

	Do you conduct routine environmental sampling for Legionella?	Have you identified any <i>Legionella micdadei</i> infections?
Ohio State Univ - The James	Water from sink faucets quarterly, a few sites on each unit	Just had our first one a couple weeks ago
City of Hope	Do a sample of sinks, showers , and cooling towers quarterly.	No
UCSD Health System	No	No
Dana Farber	At Dana-Farber,Brigham and Womens Cancer Care we test pt sink/faucet and shower water on all high risk pts/locations twice annually January and June	No
Karmanos	sample a couple times a year—sinks, showers, and sometimes ice machines	No
Moffitt	water feature in the womens clinic (against IP's advice) is tested quarterly.	No
MD Anderson	Yes, ice machines, faucets, domestic water surge tanks, decorative fountains, showers, RO system storage. Time frame for testing is mostly quarterly but some listed as annually or as requested by Infection Control.	Lab reported we've seen 3 cases of Legionella micdadei in the last 12 years. 2 cases from 2013 and 1 from 2009.
Seattle Cancer Care Alliance	On the inpatient units, the cooling towers on tested periodically	Yes, 6 cases since 2009. Includes inpatients and outpatients.

Updated 1/24/14 by spodczervinski